

MATERIAL INSPECTION REQUEST (MIR)	DISCIPLINE	LOCATION	REFERENCE NO.	REV NO.	MIR DATE
	ARCH	VIR	MCN-2414-VIR-01-MIR-0046-0	00	30 Nov-2017

CONTRACT TITLE:	Family Entertainment Centre Project, Doha Festival City	CONTRACT REF:	2414
FROM:	ATL21SEJV		
TO:	Diverse Consult		

MATERIALS/EQUIPMENT:

- Acoustic Wood wool baffle (1200X200mm)-2298nos

Material Submittal Ref. No.: MCN-2414-VIR-01-MAS-0022-1

Submittal Approval Date: 05-June-2017

Quantity: 2298 nos

Discipline: Arch

Date of Inspection: 02-DEC-2017

Time of Inspection: 11:30AM

Signature:



MANUFACTURER DETAILS:

MANUFACTURER: Acouststop
SUPPLIER: Hillpoint building solutions

INSPECTION REPORT (For Main Contractor)

	Yes	No	Signature
Physical Damage		✓	[Signature]
Details given above is correct	✓		
Conform to approval submission	✓		
Accessories Included	✓		
Details:			

Contractor's Signature: Tom [Signature]
(Mechon)

Date: 30-Nov-2017

CONSULTANT TO ENTER ACTION CODE AND REMARKS AND RETURN TO CONTRACTOR:

General Architect Structure Mechanical Plumbing Electrical/ELV Landscape Others

Comments: Approved Approved as Noted Revise & Resubmit Rejected

Remarks :

① ENSURE ALL APPROVED MATERIALS AND ACCESSORIES ARE INSTALLED PROPERLY IN GOOD CONDITION & AS PER MANUFACTURER'S RECOMMENDATION.
② ENSURE COMPLIANCE AS PER THE APPROVED SHOP DRAWING CONSIDERING METHOD STATEMENT.

Supervision Consultant's Signature:

COPIES TO: Client Consultant Contractor Subcontractor File

ENCLOSURES TO:





Note: Allow for at least fourteen working days for review.

Form No.: 2414-PQP-FM-005-0 | Oct 2017

FAMILY ENTERTAINMENT CENTRE PROJECT




DAIFERZ FOR ENGINEERING CONSULTANTS
Family Entertainment Centre
Project No.: 2414

SUBMITTAL	SUBMITTAL TRADE	SUBMITTAL PACKAGE	SUBMITTAL REFERENCE	REVIEW CYCLE	SUBMITTAL DATE
	ARCH	VIR	MCN-2414-VIR-01-MAS-0022-1	01	01-Jun-2017
CONTRACT TITLE: Family Entertainment Centre Project				CONTRACT REF:	
FROM: Mechon Trading & Contracting WLL					
TO: Diverse Consult					
SUBMITTAL TYPE					QUANTITY
<input type="checkbox"/> Shop Drawings <input type="checkbox"/> Coordination Drawings <input type="checkbox"/> Product Data <input type="checkbox"/> Construction Photographs					3
<input checked="" type="checkbox"/> Material Submittal <input type="checkbox"/> Samples <input type="checkbox"/> Design Data <input type="checkbox"/> Test Reports					
<input type="checkbox"/> Certificates <input type="checkbox"/> Manufacturer's Instructions <input type="checkbox"/> Manufacturer's Field Reports <input type="checkbox"/> Other (Method Statement)					
ITEM DESCRIPTION			REMARKS		
Material Submittal for Baffle Ceiling; MAS No. MCN-2414-VIR-01-MAS-0022-1 Manufacturer: Hillpoint					
<input checked="" type="checkbox"/> Review and Approval			<input type="checkbox"/> Resubmitted for Review and Approval		
<input type="checkbox"/> For Information			<input type="checkbox"/> For Information		
Contractor's Signature: Savin Shine 			Date: 01-Jun-2017 		
COPIES TO: <input type="checkbox"/>			<input checked="" type="checkbox"/> Consultant <input type="checkbox"/> File		
ENCLOSURES TO: <input type="checkbox"/>			<input type="checkbox"/> <input type="checkbox"/>		
CONSULTANT TO ENTER ACTION CODE AND REMARKS AND RETURN TO CONTRACTOR:					
<input type="checkbox"/> General <input checked="" type="checkbox"/> Architect <input type="checkbox"/> Structure <input type="checkbox"/> Mechanical <input type="checkbox"/> Plumbing <input type="checkbox"/> Electrical <input type="checkbox"/> Landscape <input type="checkbox"/> Others					
<input type="checkbox"/> Approved <input checked="" type="checkbox"/> Approved as Noted <input type="checkbox"/> Revise and Resubmit <input type="checkbox"/> Not Approved					
Remarks:					
PLEASE REFER TO REVIEW COMMENT SHEET ATTACHED FOR COMMENTS.					
Date: 5-6-2017					
Supervision Consultant's Signature:					Date: 05 JUN 2017
COPIES TO: <input type="checkbox"/> PM Management <input type="checkbox"/> Contractor			<input type="checkbox"/> Consultant <input type="checkbox"/> Client <input type="checkbox"/> File		
ENCLOSURES TO: <input type="checkbox"/>			<input type="checkbox"/> <input type="checkbox"/>		

Note: Allow for at least fourteen working days for review.





DIVERSE CONSULT - FEC PROJECT
Construction of Family Entertainment City

Review Comment Sheet (RCS)

Submission Ref. No.: MCN-2414-VIR-01-MAS-0022-0
Project Manager In Charge: Mohamed Abdul-Sattar
Doc or Dwg Title, Ref.No and Rev.:

Material Submitted for Review: ACOUSSTOP Rev. 0
For shopdrawings, refer to the shopdrawing's individual return code.

RCS Rev. : 1
RCS Date: 5-Jun-2017

Project Stage: Construction
Discipline: ARCHITECTURAL

Assessment Code: B

S/N	Reviewer Ref Indicator	Identification of comment's source: (title /page /clause)	Observations / Comments	Reference Number of Doc. or Dwg.	Returned Code	Comments (if any)	(Open/Closed)	Sign-Off (Open/Closed)
1	DC/RD	Project acoustic report	The proposed 1200 x 600mm baffle ceiling material - ACOUSSTOP is not acceptable. Required NRC is 0.90 and not 0.65 as per the test report. The test was conducted with 100mm back air space (considered baffles). Clarify on the acoustic performance achieving NRC 0.92 & 0.94 if achievable for baffles and if so, what specific model and update accordingly.	2414-VIR-01-MAS-0003-0	B	Enclosed Test Report signed and stamped		
2	DC/RD	Data sheet: OCS 2014, sec. 15, part 1	Clarify on thickness proposed and fire classification B. Provide test report on reaction to fire in accordance with EN-13501-1 for clarity.	2414-VIR-01-MAS-0003-0	B	Enclosed Test Report signed and stamped		
3	DC/RD	Data sheet	Clarify on the suspension system and complete accessories to be used and whether to be part of the system to be supplied.	2414-VIR-01-MAS-0003-0	B	Samples Submitted		
END OF COMMENTS.								

7
5-6-2017